

ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTL(W)/2004E&S 26		
SUBJECT: INSPECTION OF UPS	DATE 27 FEB 2004	PAGE 1	OF 3

1. SCOPE

1.1 Service Request No : ERTL(W)/2004107 DATED 16-JAN-2004

1.1.1 Service Request finalised on : 16-JAN-2004

1.2 Requested by (Name and address of organisation) ASIA POWERCOM LTD.,
A/2 SHRIJI NIKETAN,
DR. AMBEDKAR ROAD,
MATUNGA,
MUMBAI-400019

1.3 Description	Qty	Manufacturer	Type No.	Serial No.
OFFLINE UPS 2200 VA.	01 No.	POWERCOM	KIN 2200 AP	20297610304

1.4 Test specifications Customer's

1.5 Lab Ambient Not controlled.

1.6 Condition of item on receipt: Good.

1.7 Test Equipment used :

1. DMM	E&S/122
2. SCOPEMETER	E&S/125
3. Variac	--

Amendment Approved by: 

This is an amended version of Page No. 1 of 3 of Report No. ERTL (W)/2004E&S 26 issued on Feb 27 2004



ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTL(WV2004E&S 26		
SUBJECT: INSPECTION OF UPS	DATE 4 FEB 2004	PAGE 2	OF 3

2.0 Test Results

Sr.No.	Test/Parameter	Test Condition	Requirement	Observation	Remark
2.1	Input voltage range (AVR mode)	Output at rated load. (resistive load)	173 V to 275 V	Output voltage: 188 V to 238 V for an input variation of 173 V to 275 V.	---
2.2	Output voltage on battery	Output at rated load. (resistive load)	---	No load: 208.9 V Full load: 205 V	---
2.3	Transfer time	UPS switched from mains mode to inverter mode and vice versa.	---	Mains to inverter: 7.7 ms Inverter to mains: 1.1 ms	---



ELECTRONIC'S REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTL(WV)2004E& 26		
SUBJECT: INSPECTION OF UPS	DATE 4 FEB 2004	PAGE 3	OF 3

3.0 General Remarks :

3.1 All tests were carried out at customer's premises.

REPORT APPROVED BY

[Signature]
HEAD (E&S)

REPORT TESTED BY



भारत सरकार
संचार एवं सूचना प्रौद्योगिकी मंत्रालय,
सूचना प्रौद्योगिकी विभाग, मा. प. गु. प्र. निदेशालय
इलेक्ट्रॉनिकी क्षेत्रीय परिक्षण प्रयोगशाला (पश्चिम)
Government of India
Ministry of Communications and Information Technology,
Deptt. of Information Technology, STQC, Directorate.
Electronics Regional Test Laboratory (West)

ERTL(W)/CSC/1161/4391

March 1, 2004

M/s. Asia Powercom Ltd.
A/2, Shriji Niketan, Dr. Ambedkar Road
Matunga, Mumbai - 400019

Sub: AMENDMENT TO REPORT NO. ERTL(W)/2004E&S26

Ref: Your SRQ no. 2004/107 dated 16/1/2004

Dear Sir,


With reference to the above, please find enclosed herewith an amended version of page 1 of the Test report no. ERTL(W)/2004E&S26 issued on 27/2/2004.

Kindly discard the old page and insert the new one in the amended report.

Kindly acknowledge the receipt of the same

Thanking you,

Yours faithfully,


(V. R. CHAVAN)
SCIENTIST 'B'
CUSTOMER SERVICE CELL

Encl: as above

Note: For enquiries/job status, you may contact on our new telephone no. 28232439.

ELECTRONICS REGIONAL TEST LABORATORY (W/ST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTL(W)/2004E&S 26		
SUBJECT: INSPECTION OF UPS	DATE: 4 FEB 2004	PAGE: 1	OF: 3

1. SCOPE

1.1 Service Request No : ERTL(W)/2004107 DATED 16-JAN-2004

1.1.1 Service Request finalised on : 16-JAN-2004

1.2 Requested by (Name and address of organisation) : ASIA POWERCOM LTD.,
A/2 SHRIJI NIKETAN,
DR. AMBEDKAR ROAD,
MATUNGA,
MUMBAI-400019

1.3	Description	Qty	Manufacturer	Type No.	Serial No.
	OFFLINE UPS 2200 VA.	01 No.	POWERCOM	KIL 2200 AP	20297610304

1.4 Test specifications : Customer's

1.5 Lab Ambient : Not controlled.

1.6 Test Equipment used :
1. DMM E&S/122
2. SCOPEMETER E&S/125

Release

