

CERTIFICATION

Applicant : POWERCOM CO., LTD.
Address : 8F, No. 246, Lien Chen Road, Chung Ho City, Taipei Hsien, Taiwan, R.O.C.
Manufacturer : POWERCOM CO., LTD.
Address : 8F, No. 246, Lien Chen Road, Chung Ho City, Taipei Hsien, Taiwan, R.O.C.
Trade Name : PCM
Description of EUT : Uninterruptible Power System
Model Number : VGD-1000
Technical Standard EN 50091-2 : 1995 Emission
EN 55022 : 1998 Class B CISPR-22 : 1997 Class B
IEC 61000-3-2 : 2000 Power Harmonics
IEC 61000-3-3 : 1995 Voltage Fluctuation / Flicker
EN 50091-2 : 1995 Immunity
IEC 1000-2-2 : 1990 Low Frequency Signal
IEC 801-2 : 1991 Electrostatic discharge
IEC 801-3 : 1984 Radiated radio-frequency, electromagnetic field
IEC 801-4 : 1988 Electrical fast transient / burst
Report Number : HA030044-CE
Issued Date : 23-OCT-2003
Test Result : Compliance

The above equipment was tested by *HongAn* TECHNOLOGY CO., LTD., for compliance with the requirements set forth in EMC Directive 89/336/EEC (Amended by 92/31/EEC & 93/68/EEC) and the technical standards mentioned above.

Note :

1. The results of the testing report relate only to the items tested.
2. The testing report shall not be reproduced except in full, without the written approval of *HongAn* TECHNOLOGY CO., LTD.

Test by :

IH Hung CJ Lo
IH HUNG CY LO

Approve & Authorized :

L.A. HSU
L. A. HSU EMC Lab. Manager

HongAn TECHNOLOGY CO., LTD.

NO.15-1, CWEISHUH KING, CWEIPIN VILLAGE,

LINKOU,TAIPEI COUNTY,

TAIWAN, R.O.C.

TEL : 886-2-2603062

FAX : 886-2-26019259

E-mail : hualab@ms191inet.net

BSMI Registration No. : SL2-(N)-E-0023,SL2-A1-E-0023

CNLA Registration No. : 1163

Nemko authorization No. : ELA 184

VCCI Registration No. : R-144, C-1528