

ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTL(W)/2004E&S 25		
SUBJECT: INSPECTION OF UPS	DATE 4 FEB 2004	PAGE 1	OF 3

1. SCOPE

1.1 Service Request No : ERTL(W)/2004107 DATED 16-JAN-2004

1.1.1 Service Request finalised on : 16-JAN-2004

1.2 Requested by (Name and address of organisation) : ASIA POWERCOM LTD.,
A/2 SHRIJI NIKETAN,
DR. AMBEDKAR ROAD,
MATUNGA,
MUMBAI-400019

1.3	<u>Description</u>	<u>Qty</u>	<u>Manufacturer</u>	<u>Type No.</u>	<u>Serial No.</u>
	ONLINE UPS 3000 VA, 2100 W	01 No.	POWERCOM	VGD 3000	10048890310

1.4 Test specifications : Customer's

1.5 Lab Ambient : Not controlled.

1.6 Test Equipment used :
1. DMM E&S/122
2. SCOPEMETER E&S/125


Released by _____



ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTL(W)/2004E&S 25		
SUBJECT: INSPECTION OF UPS	DATE 4 FEB 2004	PAGE 2	OF 3

2.0 Test Results

Sr No.	Test/Parameter	Test Condition	Requirement	Observation	Remark
2.1	Input voltage range	Output at rated load. (1400 W resistive load)	160 to 276 VAC. Output shall be 220 V + 1 %	Complied	Complied
2.2	Output voltage on battery and waveform	Output at rated load. (1400 W resistive load)	---	219.2 V sine wave with THD of 0.9 %.	---
2.3	Overall efficiency	Input voltage: 230 V. Output at rated load. (resistive load)	---	86 %	---
2.4	Input power factor	Input voltage: 230 V. Output at rated load. (resistive load)	---	0.99	---



ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTI.(W)/2004E& 25		
SUBJECT: INSPECTION OF UPS	DATE 4 FEB 2004	PAGE 3	OF 3

3.0 **General Remarks :**

3.1 All tests were carried out at customer's premises.

REPORT APPROVED BY

REPORT


HEAD (E&S)

